



TOWER WEIGHT(Lbs)	NET WEIGHT	594
	OPERATING WEIGHT	1926
LOADING POINT(Lbs)	STAND	482
	TANK	—
PIPING	OUTLET	4"
	INLET	4"
	OVERFLOW	1"
	DRAIN	1"
	AUTOMATIC MAKE-UP	3/4"
MANUAL MAKE-UP	—	

- NOTES:
1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAINED INTO BUILDING FRESH AIR INTAKES
 2. ANCHOR BOLT BY OTHERS.
 3. CONTINUING ENGINEERING RESEARCH RESULTS IN STEADY IMPROVEMENTS. THEREFORE, THESE SPECIFICATIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE. CONSULT WITH FACTORY FOR CURRENT CERTIFIED DIMENSIONS.

APPROVED	KM LIN	06.27.2007	DWG TITLE:	TOWER DIMENSIONS AND FOUNDATION
CHECKED	NOJUN	11.06.2007	DWG DETAIL:	PCI-80
DRAWN	ZENG	06.26.2007	DWG NO.:	AFP-0080-0
ITEM	BY	DATE	DO NOT SCALE	

PROTEC COOLING TOWERS, INC.