



TOWER OVERALL DIMENSION

LOADING POINT(Lbs)	TOWER WEIGHT(Lbs)	
	NET WEIGHT	OPERATING WEIGHT
TANK	10340	27197
STAND	2429	
PIPE	7765	
OUTLET	12"	
INLET	12"	
OVERFLOW	4"	
DRAIN	4"	
AUTOMATIC MAKE-UP	3"	
MANUAL MAKE-UP	3"	

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAIN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.
3. CONTINUING ENGINEERING RESEARCH RESULTS IN STEADY IMPROVEMENTS. THEREFORE, THESE SPECIFICATIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE. CONSULT WITH FACTORY FOR CURRENT CERTIFIED DIMENSIONS.

APPROVED	DATE	DWG TITLE:
KM LIN	06.27.2007	TOWER DIMENSIONS AND FOUNDATION
CHECKED	DATE	DWG DETAIL:
NIJIN	11.07.2007	PCI-800
DRAWN	DATE	DWG NO.:
ZENG	06.26.2007	AFP-0800-0
ITEM	BY	DATE

PROTEC COOLING TOWERS, INC.